OPERATION AND MAINTENANCE GUIDES



O&M For: **XPDT00550**

Date: July 2022

XPDT00550 Code:

Description: XPRESS Diesel Tank 550 Ltr

Product Warranty:

2 years

SPECIFICATIONS

Length (mm)	Width (mm)	Height (mm)	Weight (kg)	Fill Point Dia (mm)
1200	775	800	29	50

Includes 1x 25mm outlets.

Standard

Complies with:

• Material complies with the chemical and mechanical resistance requirements of International Regulations ECE R34.01

Uses

• Diesel Fuel Storage

Statement

In line with today's focus on Ecologically Sustained Development, Green Building Initiatives and 5 Star Ratings, Promax is committed to supplying quality Liquid Storage and Handling Solutions.

Promax Plastics confirms that if these tanks are installed according to Good Management practices set out in the Promax Installation Guides, they will perform as stated throughout their intended life.

MAINTENANCE

Description	Action	Frequency
Tank Stability	Tank must remain level, foundation must not become eroded	Monthly
Tank Lid	Remains securely fitted	Bi-Monthly
Inlet/Outlet Fitting	Check Pump, if fitted, for inlet screen blockages	Bi-Monthly
Pump	Check Pump, if fitted, for inlet screen blockages	Bi-Monthly
Condensation	Remains lower than base outlet. A secondary water trap is recommended in all installations.	Half yearly or as necessary

Please note: Entry into this tank is at owners risk.



Promax Engineered Plastics Limited PO Box 749, Kerikeri 0245, New Zealand T: 0800 77 66 29 E: sales@promaxplastics.co.nz

promaxplastics.co.nz

OPERATION AND MAINTENANCE GUIDES



Responsibility: The owner/s are responsible for maintenance of the tank.

Post Storm Inspection:

Following a storm event it is recommended that a full tank inspection is carried out, please refer

the maintenance section for guidelines on this.

Debris removal programme:

If debris is identified in either a regular maintenance check or post storm inspection it is recommended that this is removed by a professional stormwater maintenance provider.

MAINTENANCE RECORDS

Date	Comments	Completed

