

# OPERATION AND MAINTENANCE GUIDES

<b>O&amp;M For:</b>	<b>UEST04000DB</b>
<b>Date:</b>	August 2023
<b>Code:</b>	UEST04000DB
<b>Description:</b>	ENDURO Septic Tank 4,000 Ltr 1.0 Dia
<b>Product Warranty:</b>	5 years

## SPECIFICATIONS

	<b>Capacity (L)</b>	<b>Length (mm)</b>	<b>Width (mm)</b>	<b>Weight (kg)</b>	<b>Manhole Dia (mm)</b>
	4000	4071	1250	175	600
<b>Standard</b>	Includes 1x 100mm outlets Complies with: <ul style="list-style-type: none"><li>• AS/NZS:1546 Standard for Septic Tanks</li></ul>				
<b>Uses</b>	• Primary Treatment of Septic Waste				
<b>Statement</b>	In line with today's focus on Ecologically Sustained Development, Green Building Initiatives and 5 Star Ratings, Promax is committed to supplying quality Liquid Storage and Handling Solutions. Promax Plastics confirms that if these tanks are installed according to Good Management practices set out in the Promax Installation Guides, they will perform as stated throughout their intended life.				

## MAINTENANCE

<b>Description</b>	<b>Action</b>	<b>Frequency</b>
Tank Lid	Remains securely fitted	Bi-Monthly
Inlet/Outlet Fitting	Remains securely fitted with no leakage	Bi-Monthly
Pump	Check Pump, if fitted, for inlet screen blockages	Bi-Monthly
Sludge Build Up	Remove sludge with vacuum truck. Re-attach tank lid securely.	Minimum 3 years or as necessary

**Please note: Entry into this tank is at owners risk.**

# OPERATION AND MAINTENANCE GUIDES



**Responsibility:** The owner/s are responsible for maintenance of the tank.

## MAINTENANCE RECORDS

Date	Comments	Completed

**Authorised By:**  
Promax Engineered Plastics Limited  
PO Box 749, Kerikeri 0245, New Zealand  
T: 0800 77 66 29  
E: sales@promax.co.nz

