OPERATION AND MAINTENANCE GUIDES



O&M For: **UXST05000**

Date: August 2023

Code: UXST05000

Description: XPRESS Septic Tank 5,000 Ltr 1.2 Dia

Product

5 years Warranty:

SPECIFICATIONS

Capacity (L)	Diameter (mm)	Length (mm)	Weight (kg)	Manhole Dia (mm)
5000	1280	5000	200	600
Includes 1y 100mm	outlots			

Includes 1x 100mm outlets

Standard Complies with:

• AS/NZS:1546 Standard for Septic Tanks

Uses • Primary Treatment of Septic Waste

Statement

In line with today's focus on Ecologically Sustained Development, Green Building Initiatives and 5 Star Ratings, Promax is committed to supplying quality Liquid Storage and Handling Solutions.

Promax Plastics confirms that if these tanks are installed according to Good Management practices set out in the Promax Installation Guides, they will perform as stated throughout their intended life.

MAINTENANCE

Description	Action	Frequency
Tank Lid	Remains securely fitted	Bi-Monthly
Inlet/Outlet Fitting	Remains securely fitted with no leakage	Bi-Monthly
Pump	Check Pump, if fitted, for inlet screen blockages	Bi-Monthly
Sludge Build Up	Remove sludge with vacuum truck. Re-attach tank lid securely.	Minimum 3 years or as necessary

Please note: Entry into this tank is at owners risk.

OPERATION AND MAINTENANCE GUIDES



Responsibility: The owner/s are responsible for maintenance of the tank.

MAINTENANCE RECORDS

Date	Comments	Completed