

OPERATION AND MAINTENANCE GUIDES

O&M For:	US1005000
Date:	July 2022
Code:	US1005000
Description:	ENDURO Super Duty Underground Tank 5,000 Ltr 1.0m
Product Warranty:	10 years

SPECIFICATIONS

	Width (mm)	Height (mm)	Length (mm)	Weight (kg)	Manhole Dia (mm)
	1250	1000	5115	410	600
Standard	Complies with: <ul style="list-style-type: none">•AS/NZS 4020: Products in contact with drinking water•AS/NZS 2070 (INT): Plastics material for food contact use•Certified to AS/ANZ 4766:2020				
Uses	<ul style="list-style-type: none">• Potable Water Storage• Retention/Detention Stormwater Management• Waste Storage				
Statement	In line with today's focus on Ecologically Sustained Development, Green Building Initiatives and 5 Star Ratings, Promax is committed to supplying quality Liquid Storage and Handling Solutions. Promax Plastics confirms that if these tanks are installed according to Good Management practices set out in the Promax Installation Guides, they will perform as stated throughout their intended life.				

MAINTENANCE

Description	Action	Frequency
Tank Lid	Remains securely fitted	Bi-Monthly
Inlet/Outlet Fitting	Remains securely fitted with no leakage	Bi-Monthly
Pump	Check Pump, if fitted, for inlet screen blockages	Bi-Monthly
Sediment Build Up	Remains lower than base outlet - if outlet flow becomes restricted remove sediment with vacuum truck. Re-attach tank lid securely.	Half yearly or as necessary

Please note: Entry into this tank is at owners risk.

Authorised By:
Promax Engineered Plastics Limited
PO Box 749, Kerikeri 0245, New Zealand
T: 0800 77 66 29
E: sales@promaxplastics.co.nz



OPERATION AND MAINTENANCE GUIDES



- Responsibility:** The owner/s are responsible for maintenance of the tank.
- Post Storm Inspection:** Following a storm event it is recommended that a full tank inspection is carried out, please refer the maintenance section for guidelines on this.
- Debris removal programme:** If debris is identified in either a regular maintenance check or post storm inspection it is recommended that this is removed by a professional stormwater maintenance provider.

MAINTENANCE RECORDS

Date	Comments	Completed