OPERATION AND MAINTENANCE GUIDES



promaxplastics.co.nz

| O&M For: | UE1004000DB | |
|----------------------|--|--|
| Date: | July 2022 | |
| Code: | UE1004000DB | |
| Description: | ENDURO Underground Tank 4,000 Ltr 1.0m | |
| Product Warranty: | 10 years | |

SPECIFICATIONS

| | Width (mm) | Height (mm) | Length (mm) | Weight (kg) | Manhole Dia (mm) |
|-----------|--|-------------|-------------|-------------|------------------|
| | 1250 | 1000 | 4115 | 175 | 600 |
| Standard | Complies with: • AS/NZS 4020: Products in contact with drinking water • AS/NZS 2070 (INT): Plastics material for food contact use | | | | |
| Uses | Portable Water Storage Retention/Detention Stormwater Management Waste Storage | | | | |
| Statement | In line with today's focus on Ecologically Sustained Development, Green Building Initiatives and 5 Star Ratings, Promax is committed to supplying quality Liquid Storage and Handling Solutions. Promax Plastics confirms that if these tanks are installed according to Good Management practices set out in the Promax Installation Guides, they will perform as stated throughout their intended life. | | | | |

MAINTENANCE

| Description | Action | Frequency |
|----------------------|--|-----------------------------|
| Tank Lid | Remains securely fitted | Bi-Monthly |
| Inlet/Outlet Fitting | Remains securely fitted with no leakage | Bi-Monthly |
| Pump | Check Pump, if fitted, for inlet screen blockages | Bi-Monthly |
| Sediment Build Up | Remains lower than base outlet - if outlet flow becomes restricted remove sediment with vacuum truck. Re-attach tank lid securely. | Half yearly or as necessary |

Please note: Entry into this tank is at owners risk.



Promax Engineered Plastics Limited PO Box 749, Kerikeri 0245, New Zealand T: 0800 77 66 29 E: sales@promaxplastics.co.nz

OPERATION AND MAINTENANCE GUIDES



promaxplastics.co.nz

| Responsibility: | The owner/s are responsible for maintenance of the tank. |
|---------------------------|--|
| Post Storm Inspection: | Following a storm event it is recommended that a full tank inspection is carried out, please refer the maintenance section for guidelines on this. |
| Debris removal programme: | If debris is identified in either a regular maintenance check or post storm inspection it is recommended that this is removed by a professional stormwater maintenance provider. |

MAINTENANCE RECORDS

| Date | Comments | Completed |
|------|----------|-----------|
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |



Promax Engineered Plastics Limited PO Box 749, Kerikeri 0245, New Zealand T: 0800 77 66 29 E: sales@promaxplastics.co.nz