# OPERATION AND MAINTENANCE GUIDES



promaxplastics.co.nz

O&M For:	UX1925000	
Date:	July 2022	
Code:	UX1925000	
Description:	XPRESS Underground Tank 25,000 Ltr 1.9M Dia	
Product Warranty:	5 years	

## SPECIFICATIONS

	Capacity (L)	Diameter (mm)	Length (mm)	Weight (kg)	Manhole Dia (mm)
	25000	1900	10540	1200	600
Standard	Complies with: • AS/NZS 4020: Products in contact with drinking water • AS/NZS 2070 (INT): Plastics material for food contact use • ARMA Underground Tank Standard				
Uses	<ul> <li>Potable Water Storage</li> <li>Retention/Detention Stormwater Management</li> <li>Waste Storage</li> </ul>				
Statement	In line with today's focus on Ecologically Sustained Development, Green Building Initiatives and 5 Star Ratings, Promax is committed to supplying quality Liquid Storage and Handling Solutions. Promax Plastics confirms that if these tanks are installed according to Good Management practices set out in the Promax Installation Guides, they will perform as stated throughout their intended life.				

## MAINTENANCE

Description	Action	Frequency
Tank Lid	Remains securely fitted	Bi-Monthly
Inlet/Outlet Fitting	Remains securely fitted with no leakage	Bi-Monthly
Pump	Check Pump, if fitted, for inlet screen blockages	Bi-Monthly
Sediment Build Up	Remains lower than base outlet – if outlet flow becomes restricted remove sediment with vacuum truck. Re-attach tank lid securely.	Half yearly or as necessary

#### Please note: Entry into this tank is at owners risk.

Authorised By: Promax Engineered Plastics Limited PO Box 749, Kerikeri 0245, New Zealand T: 0800 77 66 29 E: sales@promaxplastics.co.nz

# OPERATION AND MAINTENANCE GUIDES



promaxplastics.co.nz

Responsibility:	The owner/s are responsible for maintenance of the tank.
Post Storm Inspection:	Following a storm event it is recommended that a full tank inspection is carried out, please refer the maintenance section for guidelines on this.
Debris removal programme:	If debris is identified in either a regular maintenance check or post storm inspection it is recommended that this is removed by a professional stormwater maintenance provider.

### MAINTENANCE RECORDS

Date	Comments	Completed



Promax Engineered Plastics Limited PO Box 749, Kerikeri 0245, New Zealand T: 0800 77 66 29 E: sales@promaxplastics.co.nz