OPERATION AND MAINTENANCE GUIDES



promaxplastics.co.nz

O&M For:	EN1001000
Date:	March 2024
Code:	EN1001000
Description:	ENDURO Water Tank 1,000 Ltr
Product Warranty:	5 years

SPECIFICATIONS

	Capacity (L)	Diameter (mm)	Height (mm)	Weight (kg)	Manhole Dia (mm)
	1000	1030	1420	30	450
Standard	Includes 20mm Outlet. Complies with: • AS/NZS 4020: Products in contact with drinking water • AS/NZS 2070 (INT): Plastics material for food contact use • Certified to AS/NZS 4766:2006 Water & Chemical Tank Standard				
Uses	Portable Water StorageRetention/Detention Stormwater Management				
Statement	In line with today's focus on Ecologically Sustained Development, Green Building Initiatives and 5 Star Ratings, Promax is committed to supplying quality Liquid Storage and Handling Solutions. Promax Plastics confirms that if these tanks are installed according to Good Management practices set out in the Promax Installation Guides, they will perform as stated throughout their intended life.				

MAINTENANCE

Description	Action	Frequency	
Tank Stability	Tank must remain level, foundation must not become eroded	Monthly	
Tank Lid	Remains securely fitted	Bi-Monthly	
Inlet/Outlet Fitting	Remains securely fitted with no leakage	Bi-Monthly	
Pump	Check Pump, if fitted, for inlet screen blockages	Bi-Monthly	
Sediment Build Up	Remains lower than base outlet - if outlet flow becomes restricted remove sediment with vacuum truck. Re-attach tank lid securely.	Half yearly or as necessary	
Diasca nota: Entry into this tank is at owners risk			

Please note: Entry into this tank is at owners risk.

Authorised By: Promax Engineered Plastics Limited PO Box 749, Kerikeri 0245, New Zealand T: 0800 77 66 29 E: sales@promaxplastics.co.nz

OPERATION AND MAINTENANCE GUIDES



promaxplastics.co.nz

Responsibility:	The owner/s are responsible for maintenance of the tank.
Post Storm Inspection:	Following a storm event it is recommended that a full tank inspection is carried out, please refer the maintenance section for guidelines on this.
Debris removal programme:	If debris is identified in either a regular maintenance check or post storm inspection it is recommended that this is removed by a professional stormwater maintenance provider.

MAINTENANCE RECORDS

Date	Comments	Completed



Promax Engineered Plastics Limited PO Box 749, Kerikeri 0245, New Zealand T: 0800 77 66 29 E: sales@promaxplastics.co.nz