# OPERATION AND MAINTENANCE GUIDES

Promax
LIQUID MANAGEMENT SOLUTIONS

| | |
|---|---|
| **O&M For:** | **EN1025000** |
| **Date:** | November 2023 |
| **Code:** | EN1025000 |
| **Description:** | ENDURO Water Tank 25,000 Ltr - South Island |
| **Product Warranty:** | 20 years |

## SPECIFICATIONS

| | Capacity (L) | Diameter (mm) | Height (mm) | Weight (kg) | Manhole Dia (mm) |
|---|---|---|---|---|---|
| | 25,000 | 3750 | 2820 | 380 | 610 |
| **Standard** | Includes 2x 50mm Outlets.<br>Complies with:<br>• AS/NZS 4020: Products in contact with drinking water<br>• AS/NZS 2070 (INT): Plastics material for food contact use<br>• Certified to AS/NZS 4766:2006 Water & Chemical Tank Standard | | | | |
| **Uses** | • Potable Water Storage<br>• Retention/Detention Stormwater Management | | | | |
| **Statement** | In line with today's focus on Ecologically Sustained Development, Green Building Initiatives and 5 Star Ratings, Promax is committed to supplying quality Liquid Storage and Handling Solutions.<br>Promax Plastics confirms that if these tanks are installed according to Good Management practices set out in the Promax Installation Guides, they will perform as stated throughout their intended life. | | | | |

## MAINTENANCE

| Description | Action | Frequency |
|---|---|---|
| Tank Stability | Tank must remain level, foundation must not become eroded | Monthly |
| Tank Lid | Remains securely fitted | Bi-Monthly |
| Inlet/Outlet Fitting | Remains securely fitted with no leakage | Bi-Monthly |
| Pump | Check Pump, if fitted, for inlet screen blockages | Bi-Monthly |
| Sediment Build Up | Remains lower than base outlet – if outlet flow becomes restricted remove sediment with vacuum truck. Re-attach tank lid securely. | Half yearly or as necessary |

**Please note: Entry into this tank is at owners risk.**

**Authorised By:**
Promax Engineered Plastics Limited
PO Box 749, Kerikeri 0245, New Zealand
T: 0800 77 66 29
E: sales@promax.co.nz

# OPERATION AND MAINTENANCE GUIDES

Promax
LIQUID MANAGEMENT SOLUTIONS

**Responsibility:** The owner/s are responsible for maintenance of the tank.

**Post Storm Inspection:** Following a storm event it is recommended that a full tank inspection is carried out, please refer the maintenance section for guidelines on this.

**Debris removal programme:** If debris is identified in either a regular maintenance check or post storm inspection it is recommended that this is removed by a professional stormwater maintenance provider.

## MAINTENANCE RECORDS

| Date | Comments | Completed |
|---|---|---|
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |

**Authorised By:**
Promax Engineered Plastics Limited
PO Box 749, Kerikeri 0245, New Zealand
T: 0800 77 66 29
E: sales@promax.co.nz