

OPERATION AND MAINTENANCE GUIDES

O&M For:	E11030000
Date:	November 2023
Code:	E11030000
Description:	ENDURO Industrial Tank 30,000 Ltr - South Island
Product Warranty:	1 year

SPECIFICATIONS

	Capacity (L)	Diameter (mm)	Height (mm)	Outlets	Manhole Dia (mm)
	30,000	3820	3100	2 x50	610
Standard	Complies with: <ul style="list-style-type: none">• AS/NZS 4020: Products in contact with drinking water• AS/NZS 2070 (INT): Plastics material for food contact use• Certified to AS/NZS 4766:2006: Water & Chemical Tank Standard				
Uses	<ul style="list-style-type: none">• Potable Water Storage• Retention/Detention Stormwater Management• Industrial Applications				
Statement	In line with today's focus on Ecologically Sustained Development, Green Building Initiatives and 5 Star Ratings, Promax is committed to supplying quality Liquid Storage and Handling Solutions. Promax Plastics confirms that if these tanks are installed according to Good Management practices set out in the Promax Installation Guides, they will perform as stated throughout their intended life.				

MAINTENANCE

Description	Action	Frequency
Tank Stability	Tank must remain level, foundation must not become eroded	Monthly
Tank Lid	Remains securely fitted	Bi-Monthly
Inlet/Outlet Fitting	Remains securely fitted with no leakage	Bi-Monthly
Pump	Check Pump, if fitted, for inlet screen blockages	Bi-Monthly
Sediment Build Up	Remains lower than base outlet - if outlet flow becomes restricted remove sediment with vacuum truck. Re-attach tank lid securely.	Half yearly or as necessary

Please note: Entry into this tank is at owners risk.

Authorised By:
Promax Engineered Plastics Limited
PO Box 749, Kerikeri 0245, New Zealand
T: 0800 77 66 29
E: sales@promax.co.nz



