

# OPERATION AND MAINTENANCE GUIDES

<b>O&amp;M For:</b>	<b>PL1515000DG</b>
<b>Date:</b>	January 2024
<b>Code:</b>	PL1515000DG
<b>Description:</b>	Promax Proliq Tank 15,000 Ltr - South Island
<b>Product Warranty:</b>	1 year

## SPECIFICATIONS

	<b>Capacity (L)</b>	<b>Diameter (mm)</b>	<b>Weight (kg)</b>	<b>Height (mm)</b>	<b>Manhole Dia (mm)</b>
	15000	2980	375	2350	610
<b>Standard</b>	Includes 1x 80mm outlets Complies with: <ul style="list-style-type: none"><li>• AS/NZS 4020, AS/NZS 2070 (INT) Potable Water Standards</li><li>• Certified to AS/NZS 4766:2006 Water &amp; Chemical Tank Standard</li></ul>				
<b>Uses</b>	• Proliq Storage				
<b>Statement</b>	In line with today's focus on Ecologically Sustained Development, Green Building Initiatives and 5 Star Ratings, Promax is committed to supplying quality Liquid Storage and Handling Solutions. Promax Plastics confirms that if these tanks are installed according to Good Management practices set out in the Promax Installation Guides, they will perform as stated throughout their intended life.				

## MAINTENANCE

<b>Description</b>	<b>Action</b>	<b>Frequency</b>
Tank Stability	Tank must remain level, foundation must not become eroded	Monthly
Tank Lid	Remains securely fitted	Bi-Monthly
Inlet/Outlet Fitting	Remains securely fitted with no leakage	Bi-Monthly
Pump	Check Pump, if fitted, for inlet screen blockages	Bi-Monthly
Sediment Build Up	Remains lower than base outlet – if outlet flow becomes restricted remove sediment with vacuum truck. Re-attach tank lid securely.	Half yearly or as necessary

**Please note: Entry into this tank is at owners risk.**

