

OPERATION AND MAINTENANCE GUIDES

O&M For:	CT1010000NA
Date:	January 2024
Code:	CT1010000NA
Description:	Promax Colostrum Tank 10,000 Ltr - South Island
Product Warranty:	1 year

SPECIFICATIONS

	Capacity (L)	Diameter (mm)	Weight (kg)	Height (mm)	Manhole Dia (mm)
	10000	2190	175	3055	450
Standard	Includes 1x 50mm outlets Complies with: <ul style="list-style-type: none">• AS/NZS 4020, AS/NZS 2070 (INT) Potable Water Standards• Certified to AS/NZS 4766:2006 Water & Chemical Tank Standard				
Uses	• Colostrum Storage				
Statement	In line with today's focus on Ecologically Sustained Development, Green Building Initiatives and 5 Star Ratings, Promax is committed to supplying quality Liquid Storage and Handling Solutions. Promax Plastics confirms that if these tanks are installed according to Good Management practices set out in the Promax Installation Guides, they will perform as stated throughout their intended life.				

MAINTENANCE

Description	Action	Frequency
Tank Stability	Tank must remain level, foundation must not become eroded	Monthly
Tank Lid	Remains securely fitted	Bi-Monthly
Inlet/Outlet Fitting	Remains securely fitted with no leakage	Bi-Monthly
Pump	Check Pump, if fitted, for inlet screen blockages	Bi-Monthly
Sediment Build Up	Remains lower than base outlet – if outlet flow becomes restricted remove sediment with vacuum truck. Re-attach tank lid securely.	Half yearly or as necessary

Please note: Entry into this tank is at owners risk.



